



CERTIFICATE OF CONFORMITY

VZ5648

This Certificate is issued by the certificated contractor in accordance with the FIRAS Certification Scheme's Regulations and Procedures to indicate the compliance of a fire resistant installation at

Birmingham Childrens Hospital

A&E Observation Room, Steelhouse Lane, , Birmingham, West Midlands

It confirms that the project has been completed having full regards to the requirements of the appropriate product specification and its installation/application instructions and that the claimed performance is substantiated by appropriate test and/or assessment evidence.

Certificated Contractor

William Gough and Sons Limited
Tudor House Moseley Road
Bilston
Wolverhampton
West Midlands
WV14 6JD

Signed for and on behalf of William Gough and Sons Limited

Darren Wolverson
employee

Issue Date: 24/06/2013

Page 1 of 3





FIRAS Certificate of Conformity - VZ5648

Installation Details

Page 2 of 3

Client Details	Birmingham Childrens Hospital A&E Observation Room Steelhouse Lane Birmingham West Midlands
Completion Date	15/06/2013
Job Reference	11500
Scope of Job	Refurbishment
Products Types Used	Fire Rated Partitioning/Ceilings, Penetration Sealing
Contractors Quality Control	As inspected
Items outside scope of work of Installation Company and exceptions	Works carried out by others and not identified on the plan. Following works affecting our works from services etc.
TO ENSURE CONTINUED CONFORMANCE, THIS INSTALLATION SHOULD BE SUBJECT TO ONGOING INSPECTION & MAINTENANCE	

Certificated Contractor Details

Company Name and Address	William Gough and Sons Limited Tudor House Moseley Road Bilston Wolverhampton West Midlands WV14 6JD
FIRAS Certification Number	QF8863
Telephone	01902 657444
Name of Signatory	Darren Wolverson (employee)
FIRAS ID	S56513
Certificate Issue Date	24/06/2013
Signature	

This Certificate is issued by the certificated contractor in accordance with the FIRAS Certification Scheme's Regulations and Procedures to indicate the compliance of a fire resistant installation. It confirms that the project has been completed having full regards to the requirements of the appropriate product specification and its installation/application instructions and that the claimed performance is substantiated by appropriate test and/or assessment evidence.

This Certificate only covers work carried out up to the date of issue. Fire protection measures can be degraded over time and it is the legal responsibility of the 'Responsible Person' to ensure that fire protection must be adequately maintained and repaired/replaced over the life of the building. For details on how to carry out a risk assessment to the requirements of the Regulatory Reform (Fire Safety) Order, please contact FIRAS on 01925 646666.



FIRAS Certificate of Conformity - VZ5648

Fire Rated Partitioning/Ceilings Details

Page 3 of 3

Manufacturer	Product	Fire Resistance
Gyproc	Fireline	60 minutes

Penetration Sealing Details

Manufacturer	Product	Fire Resistance
Nullfire	Genral Fire sealing products	60 minutes